Fire Extinguisher Monthly Inspection

All portable fire extinguishers (FE) located within the facility will be visually inspected on a monthly basis. Another useful tool for locating the fire extinguishers is a map of the building with fire extinguisher locations noted. Parameters of the inspection are as follows:

- 1. Is the FE mounted off the floor, between waist and chest height, in its assigned location?
- 2. Is the FE readily identified (i.e. FE sign, red marking on the wall/post)?
- 3. Is the FE readily accessible (i.e., not blocked by product, equipment, trash, etc.)?
- 4. Check the hose nozzle for obstructions, cracks, dirt, grease, etc.
- 5. Check FE body for corrosion, leaks at seams, major dents, or mechanical damage.
- 6. Check to ensure the lock pin and plastic seal are intact.
- 7. Check pressure gauge to determine operational status (full/recharge).
- 8. Check condition of hose and hose coupling for cracks and defects.
- 9. Ensure the FE has a current tag/record indicating the date of last annual recharge inspection (inspection must be less than 1 year).
- 10. If any deficiencies are noted, tag the FE with an explanation of the problem, and remove the FE from service until the deficiency is corrected.

Extinguisher Location	Pass Yes/No	Deficiencies
		Yes/No